

Series Compensation, Power Swings, and Inverter-Based Sources and Their Impact on Line Current Differential Protection

Yiyan Xue

American Electric Power

Bogdan Kasztenny, Douglas Taylor, and Yu Xia
Schweitzer Engineering Laboratories, Inc.

Outline

- Unusual system conditions
- 87L security and dependability
- 87L dependability considerations
 - ◆ Power swings
 - ◆ Series-compensated lines
 - ◆ Weak and inverter-based sources
- Conclusion

Unusual System Conditions

- Series-compensated lines
- Power swings
- Off-nominal frequency
- Weak sources
- Inverter-based sources
- Single-pole open conditions
- Cross-country faults

87L Security

- 87L elements are inherently secure (current in is current out unless a fault)
- Security challenges in practical applications
 - ◆ CT saturation
 - ◆ Channel asymmetry and current misalignment
 - ◆ Undetected channel data errors
 - ◆ Line charging current
- Challenges are well addressed by relay design

87L Dependability Concerns


Will 87L Protection...

- Operate reliably under current inversions in series-compensated lines?
- Overrestrain during power swings?
- Lose accuracy due to off-nominal frequencies?
- Trip reliably with fault contribution from a wind farm?

Types of 87L Elements

- Differential elements respond to
 - ◆ Phase currents (87LP)
 - ◆ Negative-sequence currents (87LQ)
 - ◆ Zero-sequence currents (87LG)
- All three elements use the same data
- They may respond differently under unusual system conditions

87LQ and 87LG Do Not Decrease Security




- 87LQ and 87LG have no extra failure modes
- 87LQ and 87LG are secure under CT saturation

Key Message

Enabling 87LP, 87LQ, and 87LG

- Does not impair security
- Allows different response under unusual conditions
- Increases dependability


Dependability During Power Swings




Dependability During Power Swings

Fault
Applied


Fault
Removed




Dependability During Power Swings



Dependability During Power Swings




Why Is 87LG Element Not Affected?




Power Swings and 87L

- 87L is inherently secure
- 87LP
 - ◆ Overrestrained
 - ◆ Slow operation
 - ◆ Lower sensitivity
- 87LG and 87LQ
 - ◆ Dependable
 - ◆ Fast
 - ◆ Sensitive




Series Capacitors



- Low-current faults are a concern (MOVs do not conduct)
- Capacitors can cause a fault loop to be capacitive (current inversion)
- Asymmetrical bypass complicates current flow

Low-Current Internal SLG Fault





$$Z_{ABC} = \begin{bmatrix} -jX_C & 0 & 0 \\ 0 & -jX_C & 0 \\ 0 & 0 & -jX_C \end{bmatrix}$$




$$Z_{012} = -jX_C \cdot \begin{bmatrix} 1 & 0 & 0 \\ 0 & 1 & 0 \\ 0 & 0 & 1 \end{bmatrix}$$

Low-Current Internal SLG Fault




$$\frac{I_{0L}}{I_{0R}} = k_0 = \frac{Z_{0R} + (1 - m)Z_0}{Z_{0L} - jX_C + mZ_0}$$

Low-Current Fault Example




E	1 pu			$1 \text{ pu} \angle -40^\circ$
X_1	0.050 pu	75%	0.25 pu	0.20 pu
X_0	0.075 pu		0.75 pu	0.25 pu

Low-Current Fault Example



m (pu)	Low-Current SLG Fault	
	$87G - k_0$	$87Q - k_2$
0.1	$23.6 \angle 162^\circ$	$3.76 \angle 172^\circ$
0.2	$21.5 \angle 17^\circ$	$4.53 \angle 169^\circ$
0.3	$6.84 \angle 5.6^\circ$	$5.87 \angle 165^\circ$
0.4	$3.72 \angle 3.1^\circ$	$8.7 \angle 156^\circ$
0.5	$2.38 \angle 2.0^\circ$	$16.3 \angle 126^\circ$
0.6	$1.63 \angle 1.3^\circ$	$14.5 \angle 50^\circ$
0.7	$1.15 \angle 0.9^\circ$	$6.65 \angle 22^\circ$
0.8	$0.82 \angle 0.5^\circ$	$3.84 \angle 14^\circ$
0.9	$0.58 \angle 0.0^\circ$	$2.51 \angle 9.7^\circ$
1.0	$0.40 \angle -0.4^\circ$	$1.81 \angle 7.7^\circ$

High-Current Internal SLG Fault




$$Z_{ABC} = \begin{bmatrix} 0 & 0 & 0 \\ 0 & -jX_C & 0 \\ 0 & 0 & -jX_C \end{bmatrix}$$




$$Z_{012} = -j\frac{X_C}{3} \cdot \begin{bmatrix} 2 & -1 & -1 \\ -1 & 2 & -1 \\ -1 & -1 & 2 \end{bmatrix}$$

High-Current Internal SLG Fault




$$\frac{1+k_2}{1+k_0} = \frac{(Z_{1R} + (1-m)Z_1) - k_2(Z_{1L} - jX_C + mZ_1)}{(Z_{0R} + (1-m)Z_0) - k_0(Z_{0L} - jX_C + mZ_0)}$$

High-Current Internal SLG Fault




Example



m (pu)	Low-Current SLG Fault		High-Current SLG Fault	
	$87G - k_0$	$87Q - k_2$	$87G - k_0$	$87Q - k_2$
0.1	$23.6 \angle 162^\circ$	$3.76 \angle 172^\circ$	$6.80 \angle 42^\circ$	$2.76 \angle 106^\circ$
0.2	$21.5 \angle 17^\circ$	$4.53 \angle 169^\circ$	$3.77 \angle 18^\circ$	$2.82 \angle 73^\circ$
0.3	$6.84 \angle 5.6^\circ$	$5.87 \angle 165^\circ$	$2.31 \angle 8.1^\circ$	$2.18 \angle 37^\circ$
0.4	$3.72 \angle 3.1^\circ$	$8.7 \angle 156^\circ$	$1.53 \angle 1.8^\circ$	$1.44 \angle 8.7^\circ$
0.5	$2.38 \angle 2.0^\circ$	$16.3 \angle 126^\circ$	$1.06 \angle -2.8^\circ$	$0.98 \angle -13^\circ$
0.6	$1.63 \angle 1.3^\circ$	$14.5 \angle 50^\circ$	$0.75 \angle -7.0^\circ$	$0.71 \angle -32^\circ$
0.7	$1.15 \angle 0.9^\circ$	$6.65 \angle 22^\circ$	$0.52 \angle -11^\circ$	$0.56 \angle -49^\circ$
0.8	$0.82 \angle 0.5^\circ$	$3.84 \angle 14^\circ$	$0.36 \angle -16^\circ$	$0.48 \angle -64^\circ$
0.9	$0.58 \angle 0.0^\circ$	$2.51 \angle 9.7^\circ$	$0.23 \angle -24^\circ$	$0.42 \angle -74^\circ$
1.0	$0.40 \angle -0.4^\circ$	$1.81 \angle 7.7^\circ$	$0.14 \angle -36^\circ$	$0.38 \angle -82^\circ$

Series Compensation and 87L


- 87L is inherently secure
- Current inversion affects 87LP, 87LQ, and 87LG differently
- Enable all three elements for better dependability, sensitivity, and speed



Inverter-Based Sources

- Fault behavior not well understood
- Fault behavior driven by flexible design choices – difficult to discover
- Unease among protection engineers regarding setting selection and scheme performance
- Terminal with inverter-based source typically treated as weak terminal


Wind Farm Simulation Example



RSC = Rotor-Side Converter


GSC = Grid-Side Converter

Wind Farm Simulation Example




Wind Farm Simulation Example

SLG Fault




Wind Farm Simulation Example

LL Fault



Wind Farm Simulation Example

3P Fault



Inverter-Based Sources and 87L

- 87L is inherently secure
- Grounded transformer windings allow zero-sequence currents and support 87LG
- Inverter-based sources contribute to phase faults
- System contribution allows 87L to work reliably



Summary

- 87L protection is inherently secure
- 87LP, 87LQ, and 87LG elements respond to the same measurements
- Using all three elements does not diminish security
- 87L elements respond differently to faults under unusual system conditions
- Using all three elements increases dependability

Questions?

