

Review of Application of Ground Distance Protection


Terrence Smith, GE Digital Energy

Zhiying Zhang, GE Digital Energy

Maria Elena Lacedonia, Florida Power and Light


Steve Pitts, Florida Power and Light

Ground Distance Review



$$I \times Z - V$$

$$V_A - 1M$$



If drop to fault is greater than V , operate


Ground Distance Review

$$I \times Z - V$$


$$I_A \times Z + I_0 \times K_0 \times Z - V_A$$

$$V_A - 1M$$

$$(j \times I_0) \times e^{j\Theta}$$



Zero Sequence Compensation Factor



Zero Sequence Compensation Factor


$$V_a = V_1 + V_2 + V_0$$

$$V_A = I_1 ZL_1 + I_2 ZL_1 + I_0 ZL_0 + (V_1 F + V_2 F + V_0 F)$$

$$V_1 F + V_2 F + V_0 F = 0$$

$$V_A = (I_1 + I_2) ZL_1 + I_0 ZL_0$$

$$I_a Z = (I_1 + I_2) ZL_1 + I_0 ZL_1$$



Since the line positive and zero sequence impedance don't equal, we must compensate for that difference.

K₀ will depend on the operate equation


$$I_A \times Z + I_0 \times K_0 \times Z = V_A$$

$$K_0 = \frac{\frac{V_A}{Z} - I_A}{I_0}$$

$$K_0 = \frac{\frac{(I_1 + I_2)ZL_1 + I_0ZL_0}{ZL_1} - (I_1 + I_2 + I_0)}{I_0}$$


$$K_0 = \frac{ZL_0}{ZL_1} - 1$$

What effect does K0 have?



What effect does K0 have?

$$I \times Z - V$$




CHANNEL	MAGNITUDE
I_PhaseA	7.2033 -69.54°
I_PhaseB	1.4966 -131.73°
I_PhaseC	2.4911 -248.97°
V_PhaseA	23.087 0.00°
V_PhaseB	68.397 -123.67°
V_PhaseC	64.486 -243.80°

$$7.2 \angle -69.54 \times 3.25 \angle 85 - 23.09 \angle 0 = 6.26 \angle 94.7$$

What effect does K0 have?

$$I_A \times Z + I_0 \times K_0 \times Z - V_A$$



CHANNEL	MAGNITUDE
I_PhaseA	7.2033 -69.54°
I_PhaseB	1.4966 -131.73°
I_PhaseC	2.4911 -248.97°
V_PhaseA	23.087 0.00°
V_PhaseB	68.397 -123.67°
V_PhaseC	64.486 -243.80°

$$(7.2 \angle -69.54 \times 3.25 \angle 85) + (5.5 \angle -83 \times 1.76 \angle 3) - 23.09 \angle 0 = 3.47 \angle -70.$$

K_0 will vary depending on the operate quantity.


$$(I_A - I_0)Z + I_0 \times K_0 \times Z_0 - V_A$$

Different Relay Operate Quantity.


$$K_0 = 1 + \frac{z_0 - z_1}{3z_1}$$

Test Set K_0


Arc Impedance



Arc Impedance




Arc Impedance



Mutual Coupling

- Reduce reach of under-reaching element to not over-reach during coupling
- Set Over-reaching elements with enough margin that they reach the adjacent bus during coupling.
- Compensate the I_Z-V term with ground current from the coupled line.
- Take a mixed approach with different settings groups.

Current Supervision Level and Weak In-Feed




Current Supervision Level and Weak In-Feed

<div> <div>1</div> <div>2</div> </div>		<div>Peak</div> <div>RMS</div>	<div>Primary</div> <div>Secondary</div>	<div>Scaled</div> <div>Fixed</div>
CHANNEL		GRAPH	MAGNITUDE / ANGLE	
F1-IA		Graph 1	0.28 A -325.91°	
F2-IB		Graph 1	0.25 A -117.88°	
F3-IC		Graph 1	0.35 A -219.44°	
F5-VA		Graph 2	61.10 V 0.00°	
F6-VB		Graph 2	41.81 V -118.13°	
F7-VC		Graph 2	62.50 V -229.09°	
I_1		None	0.29 A 19.70°	
I_2		None	0.01 A 21.55°	
I_0		None	0.08 A 134.09°	

$$I_A \times Z + I_0 \times K_0 \times Z - V_A \quad \text{Compared with} \quad j \times I_0$$

Current Supervision Level and Weak In-Feed



CHANNEL	GRAPH	MAGNITUDE / ANGLE
F1-IA	Graph 1	0.28 A -325.91°
F2-IB	Graph 1	0.25 A -117.88°
F3-IC	Graph 1	0.35 A -219.44°
F5-VA	Graph 2	61.10 V 0.00°
F6-VB	Graph 2	41.81 V -118.13°
F7-VC	Graph 2	62.50 V -229.09°
I_1	None	0.29 A 19.70°
I_2	None	0.01 A 21.55°
I_0	None	0.08 A 134.09°

$$|3 \times I_0 - 0.05 \times I_1|$$

$$3 \times 0.08 - 0.05 \times 0.29 = 0.226 \text{ Amps}$$

With Positive sequence restraint it is less than the current supervision level of 0.230

Conclusion

- The type of ground protection to be used for transmission lines will depend on system conditions.
- To understand which type to use you must understand the algorithms involved and how they are affected by those system conditions