

Impact of Green Power Inverter-Based Distributed Generation on Distribution Systems

**Chuck Mozina, Consultant
Beckwith Electric Company**


DG History

- DG Started in 1978 PURPA
- Until Recently Mainly Synchronous Generators
- Some Induction Wind Machines
- Today DG Driven by Green Power
- Large Amounts of Inverter Based DGs being Installed
 - + Solar
 - + Wind

Utility Concerns with DG


- Loss of Relay System Coordination
- Overvoltages
- Maintaining Adequate Watt/VAr Feeder Voltage Regulation
- Separation Under Islanding Conditions

Islanded Operation of DG with Utility Load is Not Allowed – IEEE 1547



- **Greatly complicates restoration**
 - Requires synchronizing at utility substation
 - Inhibits automatic reclosing
- **Power quality issue**
 - DG may not be able to maintain voltage, frequency and harmonics within acceptable levels (load \neq generation; no harmonic “sink”)

DG Facility Islanding to the Utility is Allowed – IEEE 1547



- Feeder deenergizes when utility opens feeder
- Restoration responsibility on the DG
 - Requires synchronizing to utility
 - Inhibits automatic reclosing

Conventional Synchronous DG Generators' Impact on Distribution Feeders

Impact of Interconnection Transformer

- **Ungrounded Primary Transformer Winding**

- Overvoltage may be caused by DG when ungrounded primary transformer windings are applied (no ground source) and DG backfeeds once utility disconnects


- **Grounded Primary Transformer Winding**

- Ground fault current contribution caused by DG grounded primary transformer windings during utility faults
- Source feeder relaying and reclosers responding to secondary ground faults within the DG facility

Ungrounded - Primary Interconnection Transformers

Advantages

- Provide no DG ground fault backfeed for fault at F_1 & F_2
- No ground current from breaker A for a fault at F_3
- No DG ground current –helps Fuse Saving Coordination




Problems

Can supply feeder circuit from an ungrounded source after substation breaker A trips—causing overvoltage

Grounded – Primary Interconnection Transformers

Advantages

- No ground current from breaker A for faults at F_3 (delta sec. only)
- No overvoltage for ground fault at F_1
- No overvoltage for ground fault at F_2




Problems

- Provides an unwanted ground current for supply circuit faults at F_1 and F_2
- Allows source feeder relaying at A to respond to a secondary ground fault at F_3 ($Y_{\text{gnd}} - Y_{\text{gnd}}$ only)
- Ground current from DG makes fuse saving difficult

More on Wye gnd – Wye gnd Transformers – Are You Really Effectively Grounded?

Effective Grounding Test

- $X_0/X_1 < 3$
- $R_0/X_1 < 1$
- Neutral rise on Unfaulted phase less than 140%
- X_0 = Zero Sequence Reactance
- X_1 = Positive Sequence Reactance
- R_0 = Zero Sequence Resistance



Problems


Can supply the feeder circuit from a high-impedance source after substation breaker A trips, causing overvoltage for fault at F1

Inverter-Based DG Generators' Impact on Distribution Feeders

Fault Behavior of Inverter-Based DGs

- Fault Behavior Determined by Controls
- No Generalized DG Models to Predict Fault Behavior
- Two Basic Types Based on Control Scheme:
 - + Voltage Control
 - + Current Control
- Hardware Protection, in Many Cases, Determines Fault and Overvoltage Capabilities

Fault Current Contributions





- $F1$ determined by Impedance between DG and Fault – the smaller the impedance, the higher the fault current. Threshold determined by hardware. Typically $2-3 \text{ pu}$
- $T1$ depends on control bandwidth. Current control – less than $\frac{1}{2}$ cycle. Voltage control – several cycles.
- $F2$ determined Hardware design. Typically $1.0-1.3 \text{ pu}$
- $T2$ ends when DG trips or fault is cleared. Future fault-ride through will extend this time. Time can be several seconds. $T2$ time critical to distribution coordination.

Sequence Current During Unbalanced Faults

- Some Inverter Designs Generate Large Equivalent Negative Sequence Impedance
- Inverters Generally Operate Ungrounded – No Zero Sequence Ground Current
- Interconnection Transformer Grounding Still Plays a Role in Determining Ground Current for Supply Fault.

Fault Current Example:




Distance between Substation to Lateral	DG Terminal Voltage ⁽¹⁾	DG Output Current ⁽²⁾	DG Output Current Contribution (degrees that I lags behind V)	Trip Time (second)
1 Miles	0.14 pu	1.2 pu	102.5	0.12
5 Miles	0.43 pu	1.2 pu	66.0	0.12
10 Miles	0.61 pu	1.2 pu	51.8	1.8
15 Miles	0.72 pu	1.2 pu	42.1	1.8

(1), (2): Voltage and current base is rated voltage and rated current of DG

Coordination Issues:

Advantages

- Less fault current than a synchronous generator
- Makes fuse save easier
- Are there overvoltages due to neutral shift ???
- Inverters are generally ungrounded




Problems

- Provides an unwanted fault current for supply circuit faults at F_1 and F_2
- Allows source feeder relaying at A to respond to a secondary ground fault at F_3 ($Y_{\text{gnd}} - Y_{\text{gnd}}$ only)
- Ground current duration from DG difficult to determine.

Coordination Issues with Line Reclosers:

Advantages


- Less fault current than a synchronous generator
- Makes fuse save easier



Problems

- Provides an unwanted fault current for supply circuit faults at F_1 and F_2
- May cause Line Recloser to trip for fault at F_1
- Current duration from DG difficult to determine.

Wye gnd – Wye gnd Transformers – Are You Really Effectively Grounded? Traditional Utility



Problems


Can supply the feeder circuit from a high-impedance source after substation breaker A trips, causing overvoltage for fault at F1

SOLUTION ????



Interposing Transformer can provide a grounded source if $X_o/X1 < 3$ and $R_o/X1 < 1$.
But is this a good solution?

Overvoltage Potential

Simplified Schematic of Inverter Based DG




Wye gnd – Wye gnd Main Transformers & Wye –Wye Ungrounded Interposing Trans.



Voltages on the 480 V load bus during an LG fault on the customer side of a YgYg distribution transformer. Generation:load ratio = 1:1; inverter isolation transformer is YY (ungrounded).

Summary of Overvoltages for a Fault on Feeder



Solid columns correspond to grounded inverters (grounded isolation transformers), and the cross-hatched columns correspond to ungrounded inverters. Delta of dist. Transformer is on the primary

IEEE Guidance on Need for External Interconnection Protection

- **Class 1 (< 250Kw)**
 - + Rely on Internal Inverter Protection to Disconnect
 - + Check if UL 1741 Compliant
 - + Generally will trip if load to Generation is Mis-Matched by 10%
 - + Time to trip not precisely know
- **Class 2 (250Kw to 1.5 Mw)**
 - + Check to see if UL 1741 Compliant
 - + Gen./Load < 90% under minimum load conditions
 - + Time to trip not precisely know
 - + May need External Interconnection Protection
- **Class 3 (1.5 – 10 Mw)**
 - + May not be UL 1741 Compliant
 - + Gen./Load < 90% under minimum load conditions
 - + Time to trip not precisely know
 - + Probably needs External Interconnection Protection

Benefits of External Interconnection Protection

- Precise Tripping time of Inverter Fault Current Contribution can be Established Making Coordination Easier.
- Automatic Reclosing Time of Substation and Line Reclosers can be Accurately Determined.
- A Precise Reconnect Time After Restoration can be Established.
- Tripping is Independent of Inverter Control
- Changes in Utility Distribution System can be More Easily Accommodated.

Conclusions

- There are Substantial Differences Between Inverter-based and Synchronous DGs that Effect Both Fault Current and Overvoltage.
- Fault Current Behavior is Largely Determined by Inverter Control.
- Inverter-Based DGs Fault Current Magnitude is Limited to approximately 1.3 pu, while Time to Trip Depends on DG Terminal Voltage.
- Effective Grounding of Inverter DGs Location not Needed to Mitigate Overvoltage.
- Interconnection Transformer Ground Still Plays a Role in Determining Overvoltage. Wye-Grounded / Wye-Grounded Appears to be the Best Choice.
- Independent Interconnection Protection which Brackets Voltage & Frequency is Prudent for Larger Inverter-Based DGs.

Impact of Green Power Inverter-Based Distributed Generation on Distribution Systems

**Chuck Mozina, Consultant
Beckwith Electric Company**

QUESTIONS?