

# Islanding Detection with Phasor Measurement Units

Jorge Cardenas, Ilia Voloh, George Mikhael,  
Jacek Kaminski


GE Digital Energy

Texas A&M Relay Conference 2014

# Definition

“An island is defined as a condition in which a portion of an area EPS is energized solely by one or more local EPSs through the associated PCCs while that portion of the area EPS is electrically separated from the rest of the area EPS.”

IEEE Std 1547.2™-2008.




# Why Island Detection?

- Islanding operation

- The utility cannot control voltage and frequency in the island
- Possibility of damage to customer equipment
- Dangerous condition for personnel
- Reclosing into an island may result in re-tripping the line or damaging the distributed resource equipment.

- NDZ (None-detection-zone)



# Passive methods


Over/under voltage and over/under frequency:

## Advantages

- Simplicity
- Low cost

## Disadvantages

- Tripping time may be long for small mismatch
- Fails when  $P+jQ = 0$



# Passive methods


## Vector jump:

### Advantages

- Can operate faster than voltage/frequency protection
- Stable for single phase faults
- Applicable to any DG

### Disadvantages

- Can be difficult to set
- Fails when  $P+jQ = 0$



# Passive methods

## Rate of Change of Frequency:

### Advantages

- Can operate faster than voltage/frequency protection
- Applicable to any DG

### Disadvantages

- May be difficult to reliably discriminate between an islanding event and a system disturbance.
- Fails when  $P+jQ = 0$

# Passive methods


## Rate of Change of Power :

### Advantages

- Applicable to any DGs
- Can operate faster than voltage/frequency protection
- Stable for single phase faults

### Disadvantages

- Fails when  $P+jQ = 0$



$$\Delta P_G = \Delta P_L \cdot \frac{H_G \cdot S_G}{(H_G \cdot S_G + H_{EPS} \cdot S_{EPS})} \quad \text{Connected to EPS}$$

$$\Delta P_G = \Delta P_L \quad \text{Islanded}$$

Where  $H$  is the inertia constant  
and  $S$  is the capacity

# Passive methods


## Rate of Change of Voltage & Change in PF:

### Advantages

- Can operate faster than voltage/frequency protection
- Stable for system disturbances
- Applicable to any DGs

### Disadvantages

- Fails when  $P+jQ = 0$



# Passive methods


## Voltage Harmonic Monitoring :

### Advantages

- Can operate when  $P+jQ = 0$

### Disadvantages

- Load may filter the harmonic content
- Could be affected by transient phenomenon
- Only applicable for inverter-based DGs



# Active methods


## Impedance Switching:

### Advantages

- Can operate when  $P+jQ = 0$
- Applicable to any DGs

### Disadvantages

- May impact on power quality
- Coordinated operation of breaker and impedance switch



# Active methods

---

- Measurement of the system impedance
- Impedance detection at the determined frequency
- Frequency variation, jump
- Frequency derivatives
- Active Frequency Drift (Sandia Frequency Shift)
- ENS or MSD, two switching devices in series are independently monitored and controlled

# Communications methods


## Power Line Carrier:

### Advantages

- Can operate when  $P+jQ = 0$
- No impact on power quality

### Disadvantages

- Requires installation of transmitter and receiver equipment
- May mal-operate during a system fault



# Communications methods


## Signal Produced by Disconnect Switch:

### Advantages

- Can operate when  $P+jQ = 0$

### Disadvantages

- Requires the installation of a transmitter into the EPS.
- Expensive and could involve significant permitting and design complications.





# Summary of methods

---

- Most passive schemes cannot guarantee fast operation as the power flow across the breaker approaches zero.
- Many active schemes can quickly detect an island even when the power flow through the breaker is zero prior to islanding.
- Of these schemes several are applicable only for inverter-based DGs.
- The remaining schemes have power quality, scalability or security issues.


# Research

Model of distribution network contains photovoltaic, wind and other renewable sources, as well as several loads spread all of the system.



# Research


## RTDS PV model



Description	Value	Unit
Component name	DefaultName	
Open Circuit Voltage [V]	21.7	V
Short Circuit Current [A]	3.35	A
Voltage at Pmax [V]	17.4	V
Current at Pmax [A]	3.05	A
Assignment of Model to Processor Card	Automatic	
-if Manual: Begin on Processor Card	1	1 to 6
-if Manual: Begin on Processor	A	
-if Auto: Begin on Processor	Either	
Solve Model on card type:	GPC/PB5	

Buck Converter

2-Level low loss  
DC/AC converter




# Preliminary Test Results

THD Differential is monitored

Case #1

Power generated inside the island is higher than its consumption

$$P_{gen} > P_{load}$$




# Preliminary Test Results

## Case #2

Power generated inside the island is lower than its consumption

$$P_{gen} < P_{load}$$




# Preliminary Test Results

## Case #3

Power generated inside the island is almost equal to consumption

$$P_{gen} \approx P_{load}$$



# Solution

---

Proposed way for Island  
Identification - Combine most  
effective passive methods with  
synchrophasor technology

# Solution

- ***Voltage Angle Change:***

Angle variation during normal operation is in the range of  $\pm 40^\circ$  approx. During Island value is higher and non affected by  $\Delta P + j\Delta Q$ .



- ***Voltage Magnitude Change:***

Magnitude shifting turned out as an effective method in high power mismatches which can decrease detection time substantially.



- ***Voltage THD Differential:***

New idea which can detect island condition immediately and independently on the power flow in point of disconnection.

= **DETECTION IN MOST OPERATION CONDITIONS**

# Algorithms Developed

Phasors used for algorithms are the result of the mathematical Clarke Transformation, which simplifying three-phase system measurements into one phase system. Clark transform is given by the following equations:

$$S_X = \frac{2 \cdot S_A - b \cdot S_B - b^* \cdot S_C}{3};$$

## 3 inputs into algorithm

- Voltage Angles:  $\delta_{v1}(t), \delta_{v2}(t)$
- Voltage Magnitudes:  $V_1(t), V_2(t)$
- Per phase THDs from both sides:  
 $THD_{Va_1}(t), THD_{Vb_1}(t), THD_{Vc_1},$   
 $THD_{Va_2}(t), THD_{Vb_2}(t), THD_{Vc_2}(t)$

# Implementation

## First algorithm


Angle difference

$$\delta_{\text{PMU1 VClarke}} - \delta_{\text{PMU2 VClarke}}$$



Magnitude difference

$$M_{\text{PMU1 VClarke}} - M_{\text{PMU2 VClarke}}$$



# Implementation

## Second algorithm


Angle Difference (AD)

$$\delta_{\text{PMU1 VClarke}} - \delta_{\text{PMU2 VClarke}}$$

↔

Rate of Change of AD

$$\frac{\Delta \text{ Angle Difference}}{\Delta t}$$




## Third algorithm

$$\begin{aligned} THD_{Diff}(t) &= \\ &= [THD_{Va_1}(t) + THD_{Vb_1}(t) + THD_{Vc_1}(t)] \\ &- [THD_{Va_2}(t) + THD_{Vb_2}(t) + THD_{Vc_2}(t)] \end{aligned}$$


# Implementation

All the methods are implemented in the soft PDC logic software



# Algorithm results

T(ms)




Pload/Pgen

# Tests in an external laboratory

Implemented algorithms has been tested in a small test grid in the external laboratory, with real inverter connected.


Result = **passed**



# Tests in an external laboratory

Also sensitivity for other conditions including fault events has been tested

Result = **passed**



# Conclusions

- Paper presents a research result, including a novel THD differential algorithm which has been presented as an enhancement of present methods for decreasing the total Non Detection Zone.
- Developed methods have been tested with a Real Time Digital Simulator and scaled grid model with several scenarios.
- The laboratory test results were positive, which renders the methods ready to be used in the field. The thresholds and time delays should be set based on real system readings and in coordination with other protection functions installed in the system.
- PMU and PDC can communicate via radios, which results in a flexible and cost efficient installation. Present and future work involves testing different radio techniques for the best cost effectiveness $\leftrightarrow$ performance ratio.

Thank You

Questions?