

Incorporating Arc-Flash Mitigation into the Design of New and Existing Facilities

Presented to:

***67th Annual Conference for Protective Relay Engineers
Texas A&M University
April 2014***

Introduction

- Has it really been 10 years?
- So much has changed
- So much remains the same

Short History of Arc-Flash Standard and Papers

- 1985 – Ralph Lee published the first paper *The Other Electrical Hazard, Electric Arc Blast Burns*.
- 1987 - Ralph Lee published the paper, *Pressures Developed from Arcs*.
- 1997 – Bingham, Doughty and Neal publish the paper *Testing Update on Protective Clothing and Equipment for Electric Arc Exposure*.
- 2000,- Doughty, Floyd, and Neal published *Predicting Incident Energy to Better Manage the Electric Arc Hazard on 600-V Power Distribution Systems*
- 2000 – NPFA-70E *Standard for Electrical Safety Requirements for Employee Workplaces* 2000 Edition.
- 2002 - IEEE Std. 1584-2002, *IEEE Guide for Performing Arc-Flash Hazard Calculations*.

Short History of Arc-Flash Standard and Papers

- 2004 – NFPA-70E *Standard for Electrical Safety in the Workplace* 2004 Edition.
- 2004 - IEEE Std. 1584a-2004, *IEEE Guide for Performing Arc-Flash Hazard Calculations – Amendment 1*.
- 2005 – NFPA 70 *National Electric Code* 2005 Edition.
- 2009 - NFPA-70E *Standard for Electrical Safety in the Workplace* 2009 Edition.
- 2011 - IEEE Std. 1584b-2011, *IEEE Guide for Performing Arc-Flash Hazard Calculations – Amendment 2*.
- 2012 - NFPA-70E *Standard for Electrical Safety in the Workplace* 2012 Edition.
- Future?

Where are we today?

- PPE Standards and options have evolved significantly over the last 10 years and will continue into the future.
- Mitigation options have expanded and will continue to evolve into the future.
- Facilities can be designed that will mitigate incident energies that will work regardless of changes in standards.



Reducing Incident Energy Through Design Practices

- **Passive Mitigation**
- **Active Mitigation.**
- **Temporary Mitigation.**

Passive Mitigation

- **Main Device Isolation**
 - ◆ Must be truly isolated, no common bus areas
 - ◆ Must Isolate ALL Sources
 - ◆ Very Important at Service Entrances and Utility Intertie points

Mains Isolation





A TYPICAL ARC FLASH EVENT



A TYPICAL ARC FLASH EVENT



A TYPICAL ARC FLASH EVENT



A TYPICAL ARC FLASH EVENT



A TYPICAL ARC FLASH EVENT




A TYPICAL ARC FLASH EVENT



Passive Mitigation

- **Main Device Selection**
 - ◆ Main Device type can affect incident energy
 - ◆ Main device settings can affect incident energy

Main Device Selection



0.3s Delay
17 cal/cm²


1.49s Delay
72 cal/cm²

0.39s Delay
22 cal/cm²



1.45s Delay
70 cal/cm²


Main Device Settings



Passive Mitigation

- **Transformer Impedance Selection**
 - ◆ Higher impedance used to lower fault currents (lower fault ratings = lower cost equipment).
 - ◆ Higher impedance results in higher losses (heat)
 - ◆ Higher impedance result in longer arcing fault trip time (higher IE).

Transformer Impedance




0.06s Delay
0.9 cal/cm²

2s Delay
30 cal/cm²

Passive Mitigation Failure

- **High Resistance Grounding (HRG)**
 - ♦ Reduces the Probability of an arc-flash. It does not reduce the magnitude (actually higher).
 - ♦ Requires Isolation transformers for loads that require solid grounding (ie: lighting), result in higher IE.

HRG Affect on Lighting Panels




0.02s Delay
0.23 cal/cm²

2s Delay
7.2 cal/cm²

Active Mitigation

- ◆ Does not compromise selectivity
- ◆ Always active
- ◆ Fast clearing times
- ◆ Still requires main isolation
- ◆ Examples
 - Differential Protection
 - Communications Based protection (Zone Interlocking)
 - Arc Detection

Active Mitigation




Temporary Mitigation

- ♦ Can significantly reduce incident energy
- ♦ Will compromise selectivity when active
 - Add visual or communications based notification so that it is not left active
 - Consider mechanical interlocks
- ♦ Depending on location may not require main isolation
- ♦ Effectiveness not guaranteed, it must be analyzed.
- ♦ Can be applied across transformers

Apply Maintenance Mode on the High Side of a Transformer

- ◆ Must be able to added either as discrete device or an additional function.
- ◆ The operating device must be able to safely interrupt the fault (not a load breaker device).
- ◆ Must be able to be set above load, but well below the expected arcing fault current.

Temporary Mitigation



No Mitigation
1.93s Delay
93 cal/cm²

Maint. Mode
0.1s Delay
5.7 cal/cm²

Requiring Mitigation in Design and Construction

- ◆ It is easier and less expensive to incorporate mitigation into a design before it is built instead of trying to fix it once it is installed. This can be accomplished by requiring it both in the design and construction specifications.
- ◆ The specification must require mitigation to a PPE level that meets the site-specific safety requirements.


Requiring Mitigation in Design

- ◆ The specifications must require complete analysis of the mitigation in the design process, prior to equipment purchase, and the as-built configuration.
 - Existing Facilities require data collection by personnel familiar with the analysis and codes to identify condition or code based issues that might affect the design or analysis
 - Personnel collecting data must mark-up one-lines to reflect the as-found conditions

Equipment Specifications

- ◆ Require Isolated Main Devices.
- ◆ Require Isolation in Unit Transformers.
- ◆ Require designs that direct arc-energies away from personnel.
- ◆ Require sufficient number and locations for inspection windows to reduce the number of time covers have to be removed.
- ◆ Require devices with integral metering for all locations where load checks are required.

What We Want to Avoid



What We Want to Avoid



Conclusions

- There are ways to reduce incident energies in both new and existing facilities.
- The configurations and methods discussed here are **SOME** of the ways this can be accomplished.
- To make this happen it **MUST** be written in to all new specifications

Thank You

Questions?

chris.Inshaw@southwestenergysystems.com

559-978-0019