

Coordinating Dissimilar Line Relays in a Communications-Assisted Scheme

William Tucker


American Electric Power

Andrew Burich, Michael Thompson,
RadhaKiranMaye Anne, and Sneha Vasudevan
Schweitzer Engineering Laboratories, Inc.

Outline

- Introduction to AEP
- Comparison of pilot schemes
- Ground element sensitivity
- Response of elements
- Case studies
- Recommendations

Introduction to AEP System



Indiana Michigan Power

Kentucky Power

Public Service Company of Oklahoma

Southwestern Electric Power Company

AEP Ohio

AEP Texas

Appalachian Power Company

AEP Line Relay Standards

- Two microprocessor-based relays from different manufacturers
- At least one pilot scheme at 115 kV or above, two at extra-high voltage (EHV)

Most Common Communications-Assisted (Pilot) Schemes at AEP

- Directional comparison blocking (DCB)
- Permissive overreaching transfer trip (POTT)
- Line current differential


Review of Pilot Schemes

- Preference for identical line relays
- Common elements in pilot schemes
 - ◆ Mho phase distance
 - ◆ Mho ground distance
 - ◆ Directional ground overcurrent
- Dissimilar relays in pilot scheme

Comparison of Pilot Schemes


Elements / Logic	DCB	Traditional POTT	Hybrid POTT
Forward-looking pilot (tripping) elements	Yes	Yes	Yes
Reverse-looking pilot (blocking) elements	Yes	No	Yes
Echo logic	No	No	Yes
Current reversal logic	Yes	No	Yes
Weak infeed trip logic	No	No	Yes
Coordination necessary?	Yes	No	Yes

Example System




All Values Are in Primary Ohms

Effect of Remote Infeed



$$Z_{app} = Z_L + \frac{(I_1 + I_2) \cdot R}{I_1}$$

Fault Coverage of Ground Distance Elements



Response of Elements

- CTD – speed of response, not different sensitivities
- External versus internal faults
- Coordination
 - ◆ At maximum torque angle
 - ◆ In primary quantities
 - ◆ Fault detectors for directional elements
- Faults at the ragged edge

Element Sensitivity Concerns

Distance Elements

- Elements (mho, quad, compensator)
- Memory time constants
- Phase element supervision – phase or sequence quantities
- Ground element supervision – more options
- Limited reach – $(120 \text{ to } 300\%) \cdot Z_L$
- Risk – acceptable if principles are similar

Element Sensitivity Concerns


Directional Ground OC Elements

- Very sensitive
- Greater variation in principle of operation and supervisory elements
 - ◆ $3V_0$, $3I_0$, $3V_2$
 - ◆ Order selection versus fixed
 - ◆ $V \cdot I$ versus V/I
- Risk – unacceptable

Ground Element Sensitivity

- System stability versus personnel safety
- 67 versus 21
- Factors affecting ground distance sensitivity
 - ◆ Infeed across fault resistance
 - ◆ Polarization technique
 - ◆ Expansion and source impedance
 - ◆ Reach setting

67 Versus 21 Sensitivity



Case Study 1



All Values Are in Primary Ohms

- DCB, Different manufacturers
- POTT, Same manufacturer but different vintage

Primary DCB Scheme

- L1 and R1 – V1MEM polarized phase and ground distance elements
- L1 – fixed torque directional element
- R1 – impedance (order-based) directional element

Alternate POTT Scheme

Elements / Logic	L2	R2
Mho phase distance elements	Compensator distance phase	V1MEM polarized
Directional element	Torque-based	Negative-sequence impedance-based
Mho ground distance elements	Not included	Included
Echo logic	Not included	Included


Case Study 1 Recommendations

- Primary DCB scheme – disable dissimilar ground directional elements
- Alternate POTT scheme
 - ◆ Disable echo logic in R2
 - ◆ Operate as traditional POTT scheme due to
 - Dissimilar operating principles of distance elements
 - Absence of echo logic in L2

Overall Scheme Advantages and Disadvantages

- Advantages
 - ◆ More security
 - ◆ High sensitivity for resistive ground faults achieved by alternate POTT scheme
 - ◆ Open breaker fault clearance in primary DCB scheme
- Disadvantages – none

Case Study 2



All Values Are in Primary Ohms

- DCB, Same manufacturer, different philosophies
- POTT, Different manufacturer

Different Utility Philosophy

- Utility A – forward pilot reach is 200% of ZL, no preference for quadrilateral elements
- Utility B – forward pilot reach is 120% of ZL, preference for quadrilateral elements and directional OC elements
- Primary DCB scheme – same relays at either end

Alternate POTT Scheme

Elements	L2	R2
Mho or quadrilateral element	Either can be enabled	Both can be enabled
Directional element	Fixed torque	Impedance (order-based)
Phase and ground distance elements	Positive-sequence memory polarized	Positive-sequence memory polarized

Case Study 2 Recommendations

Primary DCB Scheme

- Enable mho distance and directional OC elements in both relays
- Disable quadrilateral elements in both relays (one utility already has them disabled by default)

Case Study 2 Recommendations

Alternate POTT Scheme

- Disable echo logic and enable directional OC

OR

- Disable directional OC and enable echo logic

Solution 1: Disable Echo Logic and Enable Directional OC Elements

- Advantages
 - ◆ Increased fault resistance coverage
 - ◆ No coordination required
- Disadvantages
 - ◆ Both ends must declare forward fault
 - ◆ Slower clearance of internal faults when either terminal is weak / open

Solution 2: Disable Directional OC Elements and Enable Echo Logic

- Advantages
 - ◆ Rapid clearance of internal faults when
 - Either breaker is open
 - Either terminal sees high-resistance fault
 - ◆ Maximum use of ground distance elements
- Disadvantage – lesser fault resistance coverage

Summary

- Distance elements
- Directional OC elements
- High resistance faults
- Echo logic – fault resistance coverage is maximized
- Hybrid POTT schemes – coordination necessary

Recommendations

- DCB scheme with dissimilar relays
 - ◆ Disable directional OC elements
 - ◆ Enable distance elements in pilot scheme if similar principles are used
- POTT scheme with dissimilar relays
 - ◆ Disable echo logic and enable directional OC elements
 - ◆ Disable directional OC elements and enable echo logic

Questions?

