



Improving BES Reliability at Large Generating Station Locations

By Thomas E. Baker


Copyright © CRC Press 2012

Three Areas of Concern at Large Generating Stations



- High voltage switchyard instability
- Many high voltage switchyard schemes not backed-up
- Many important protection functions not applied

Switchyard Configurations

Double Breaker Double Bus



Breaker & One Half




Lack of High Voltage Switchyard Backup protection

- Bus differentials are often not backed up
- Unit, transformer, and feeder differentials are often not backed up
- Breaker failure time delays often exceed critical clearing time

Critical Clearing Times

- Close in 3-phase fault – similar to full load rejection
- Typical clearing times for close in three phase fault:
 - Combustion turbine – as little as 6 cycles
 - 2 pole large coal unit – around 10 cycles
 - 4 pole large nuclear unit – around 12 cycles
 - Ground faults – three times longer
 - Phase-phase & double line to ground cycles less than ground


Line protection is normally backed-up



Single Relay Scheme Backup Clearing

- Zone 2 line relays normally set for 24 cycles.
- Transformer bank high side overcurrent usually have more than 1.0 seconds of time delay.
- Breaker failure time delays may be longer than the critical clearing times.
- Generator negative phase sequence and backup impedance have long time delays that may not prevent instability.
- Remote zone 2 and directional ground overcurrent protection may not have the sensitivity to detect the fault depending on the number of lines and sources.

Current Distribution & Infeed Ohms



Infeed Ohms

Pu Z_A Pu Z_B

Base Amps

Pu Z_C

A B

$Z_T = \frac{(Z_A \times Z_B)}{(Z_A + Z_B)} + Z_C$

$I_T = \frac{Base I}{Z_T}$

Amps from A (I_A) = $\frac{Z_B}{(Z_A + Z_B)} \times I_T$

Ohms from A = $Z_A + \left(Z_C \times \frac{I_T}{I_A} \right)$

Notes:
Useful for setting impedance relays functions involved with multiple sources.

Proposed Switchyard Zone 1 Impedance Schemes

For GSU Differential:

- Looks from the switchyard to the unit.
- Provides backup for the unit differential protection.
- If the unit differential fails to clear faults properly, there may be a collapse of the electrical system or islanding.
- Should not be able to see unit auxiliary transformer low side faults and generator under excitation events.

For RAT Transformer Differential:

- Looks from the switchyard to the RAT
- Provides backup for the differential protection.
- If the RAT transformer differential fails to clear faults properly, there may be a collapse of the electrical system or islanding.
- Should not be able to see RAT transformer low side faults.

For Bus Differentials:

- Use line CTs to feed digital current differential
- Does not overlap, but line protection includes breaker and is backed up


For Breaker Failure Schemes:

- Usually enough margin to reduce time delays

Generator Backup Impedance


No Industry Consensus

- Thermally protects generators from 3-phase transmission system faults and disturbances that do not clear properly.
- Provides backup for generator and transformer 3-phase short circuits.



(21) Backup Impedance

X_{d'} Ohms Sec. .67 pu Ohms Sec.



Zone 1 Forward = $0.5 \times \text{Xfmr. Ohms Sec.}$ 1.053200

Zone 1 Offset = $0.1 \text{ Ohms (neutral CT)}$
 $X_{d'} \text{ Ohms Sec. (output CT)}$ 0.1

Zone 1 Angle 75

Zone 1 Time Delay Seconds 0.1

Zone 2 Forward = 0.67 per unit 13.339780

Zone 2 Offset = $0.1 \text{ Ohms (neutral CT)}$
 $X_{d'} \text{ Ohms Sec. (output CT)}$ 0.1

Zone 2 Angle 75

Zone 2 Time Delay Seconds 2.0

Notes:

All ohms are generator base secondary.

Z1 Forward reaches halfway into transformer.

Z1 Time ensures differential targets.

Z2 Forward = 150% rated MVA = .67 pu.

Z2 Time ensures downstream coordination and thermal protection.

Z2 is a 3-Phase setting (Xfmr. comp. not necessary) and relies on (46) function to protect the machine from prolonged unbalanced faults.

Important Functions Often Not Applied

- Out-Step
- Inadvertent Energization
- Pole Flashover
- Slow-Breaker Closing During Synchronizing