


# Does Every Millisecond Really Count – A Comparison of Protection Based Arc Flash Mitigation Techniques

Terrence Smith, GE Grid Solutions  
Chris Burnette, GE Industrial Solutions  
Marcelo Valdes, GE Industrial Solutions


2016 Texas A&M Relay Conference

# Background

## One-Line Diagram - IE Calculator (Edit Mode)



# Background



# Arc-Flash Relay controlling 3 cycle Breaker

---


- Total time to clear is influenced by relay as well as breaker
- If lockouts are used, that time should also be included
- Light sensing relays are fast, but must be supervised to prevent mis-operation
- Depending on the supervision, operation of arc sensing relays can take from 4-12ms
- The type of relay output contact should also be considered

# Arc-Flash Relay controlling 3 cycle Breaker

- A relay with a 4ms algorithm and a solid state output controlling a three cycle breaker has a total clearing time of 54.1 milliseconds
- For a 25KA fault on a 480V system this gives an incident energy of 4.8 Cal/cm<sup>2</sup>
- A relay with a 8ms algorithm and a solid state output controlling a three cycle breaker has a total clearing time of 58.1 milliseconds and 5.0 Cal/cm<sup>2</sup>
- Algorithm matters, but not enough to put you into a different clothing category




# Zone-Selective Interlocking & 3 Cycle Breaker



# Zone-Selective Interlocking & 3 Cycle Breaker

- $t_{pkp} = \frac{1.33}{MOP}$
- Element operate time
- Blocking signal asserted in logic
- Output contact
- Time to clear with a 3 cycle breaker



# Zone-Selective Interlocking & 3 Cycle Breaker

- Similar and dis-similar algorithms require different time delays
- Dis-similar with upstream time to operate 40ms & 4 ms contact. Fault current = 1.8 times pickup, 12ms pickup & 3 cycle breaker total clear = 106 milliseconds. Energy = 7.5@4KV & 12@480V.
- Similar with a time delay of 4ms...operate time is 16ms & TCC of 66.7ms. Energy = 5.8@4KV & 4.0@480V.
- The algorithms determine the time delay which can impact the incident energy



# Bus Differential

---

- Three cycle breaker gives a clear time of 66.7ms
- 5.8 Cal/cm<sup>2</sup> for 25KA & 480V system
- 4 Cal/cm<sup>2</sup> for 25KA & 4KV system

# Reduced Energy Let Through

- Operate times will be the same as instantaneous element....about a cycle
- Since has same operate time as a bus differential will have similar incident energy
- Advantages:
  - Easy to configure
  - Works for all faults
- Disadvantages
  - You have to remember or be reminded to turn the switch on and off

# Case Study Results

<b>Solution</b>	<b>IE with 3 cycle breaker in Cal/Cm2</b>	<b>Clearing Time in milliseconds</b>	<b>IE with 5 cycle breaker in Cal/Cm2</b>	<b>Clearing Time in milliseconds</b>
480V 4ms Arc-Flash Sensor @ 25KA	4.8	54.1	7.5	87.4
480V 8ms Arc-Flash Sensor @ 25KA	5.0	58.1	8.0	91.4
4KV 4ms Arc-Flash Sensor @25KA	3.4	54.1	5.3	87.4
4KV 8ms Arc-Flash Sensor @25KA	3.5	58.1	5.4	91.4
480V Zone Interlocking 106ms sc@25KA	12.0	106.0	OVER 12	139.3
4KV Zone Interlocking 106ms sc@25KA	7.5	106.0	OVER 12	139.3
480V Zone Interlocking 56ms sc@25KA	5.8	66.7	8.7	100.0
4KV Zone Interlocking 56ms sc@25KA	4.0	66.7	6.0	100.0
480V Low Imp Bus Diff @25KA	5.8	66.7	8.7	100.0
4KV Low Imp Buss Diff @25KA	4.0	66.7	6.0	100.0

# Conclusions

---

- For most schemes, the type of solution you employ won't affect your clothing category
- Care should be taken with zone interlocking to avoid mis-coordination and fast operation
- Understand the advantages and disadvantages of each solution and make decisions based on those parameters

Thank You

Questions?