


Man-Made Faults – Line Protection Operation for an Unintended Phase Cross-Connect Condition


Jon Larson and Ryan McDaniel
Schweitzer Engineering Laboratories, Inc.



System One-Line Diagram

Compensator Distance Relays

Electromechanical



Digital

$$A = V_{AB} - Z_{1R} \cdot I_{AB}$$

$$B = V_{BC} - Z_{1R} \cdot I_{BC}$$

$$T = \text{Im} \left[A \cdot (B)^* \right]$$

$$Z_{1R} = r \cdot Z_1 \angle \text{MTA}$$

Negative Torque → Operates

R = Restraint (A Leads B)

O = Operate (B Leads A)

Symmetrical Component Analysis

Compensated
Voltages

$$V_1C = V_{1A} - Z_{1R} \cdot I_{1A}$$

$$V_2C = V_{2A} - Z_{1R} \cdot I_{2A}$$


Balance Point

$$\frac{V_2C}{V_1C} = 1 \angle \theta$$


Phase Reversal
(Relay Operates)

$$\frac{|V_2C|}{|V_1C|} > 1$$

Example System for Compensator Relay Evaluation




Compensator Relay Evaluation




Why Use Compensator Elements?

- Different operating principle
- Delta-wye transformer
- Reclosing blocked for three-phase faults
- Open-delta VTs

Relay 1 Event Analysis





Relay 2 Event Analysis




Relay 2 Phasor Analysis

Prefault Voltages

Fault Voltages




Relay 3 Event Analysis




Symmetrical Component Analysis

Phase-to-Phase Fault at Electrical Center




Symmetrical Component Analysis

Cross-Connect Fault at Electrical Center




Symmetrical Component Analysis

Phase-to-Phase Fault Not at Electrical Center



Symmetrical Component Analysis


Cross-Connect Fault Not at Electrical Center




Symmetrical Components Summary

- For all cross-connect locations, fault current is calculated with fault at electrical center
- Relay voltage depends on relay location relative to electrical center and cross-connect fault
- $|V_2|$ exceeds $|V_1|$ when relay is located between electrical center and cross-connect fault

Relay Performance During Cross-Connect Fault





Relay Performance During Cross-Connect Fault




Compensator Distance Element

- Element operates when relay experiences phase reversal
- Phase reversal occurs when relay is located between electrical center and cross-connect fault



Negative-Sequence Impedance Directional Element

$$Z_2 = \frac{\text{Re} \left[V_2 \cdot \overline{(I_2 \cdot 1 \angle \text{MTA})} \right]}{|I_2|^2}$$




Directional element correctly identifies location of
cross-connect fault

Self-Polarized Mho Element

Measures Impedance to Electrical Center

$$M_{BC} = \frac{\text{Re}(V_{BC} \cdot \overline{V_{BC}})}{\text{Re}(1 \angle MTA \cdot I_{BC} \cdot \overline{V_{BC}})}$$



- Element is not applied in modern digital relays
- Denominator determines direction
(+ → Forward)

Memory-Polarized Mho Element


Measures Impedance to Electrical Center

$$MBC_{(mem)} = \frac{\text{Re}\left(V_{BC} \cdot \overline{V_{BC(mem)}}\right)}{\text{Re}\left(1\angle MTA \cdot I_{BC} \cdot \overline{V_{BC(mem)}}\right)}$$


Electrical center → Relay → Cross-connect fault
Always operates

Relay → Cross-connect fault → Electrical center
May operate

Cross-connect fault → Relay
Will not operate



Summary for Example System



Relay 1 and 2 Element Performance

Actual Event

Z_2		Mho		Compensator	
Relay 2	Relay 1	Relay 2	Relay 1	Relay 2	Relay 1
Forward	Forward	−0.36 ohms secondary	0.448 ohms secondary	NA	0.448 ohms secondary
Fault on line		Fault behind Relay 2		Fault behind Relay 2	

Conclusion

- Cross-connect faults are similar to phase-to-phase faults, but different
- $|V_2|$ can exceed $|V_1|$, which leads to voltage phase reversal
- Compensator distance elements operate for voltage phase reversal regardless of setting

Conclusion

- Compensator distance elements are dependable for a cross-connect fault, but not secure
- Security can be improved by applying fault detectors or by supervising with negative-impedance-based directional elements
- Line current differential schemes are secure and dependable for cross-connect faults

Conclusion

- Good engineering judgment is required to limit exposure to problems caused by cross-connect faults
- Proper operating procedures must also be followed to limit exposure to these faults

Questions?

