

Protection System for a Wind Generation Plant in Panama: Challenges and Solutions

Darío Vila

Instalaciones y Servicios CODEPA S.A.

Eliseo Alcázar, Jorge Juárez,
Pedro Loza, and Héctor J. Altuve
Schweitzer Engineering Laboratories, Inc.

Outline


- Introduction
- Power system description
- P&C system
- Power system modeling
- Protection coordination
- Actual fault event
- Conclusion



Penonomé Wind Power Plant

- Location 70 miles southeast of Panama City
- Capacity
 - Total – 337.5 MW (135 WTGs)
 - In service – 270 MW (108 WTGs)
- Power system
 - Two step-up 120/140 MVA, 230/34.5 kV transformers
 - Twelve 34.5 kV collector circuits

Power System One-Line Diagram



Wind Power Plant Grounding

- Two 34.5 kV zig-zag transformers
 - Connection to low side of step-up transformers
 - 1,000 A ground fault contribution each
- Three 34.5/0.48 kV grounded-wye/delta banks
 - Connection to collector circuits
 - 1,100 A ground fault contribution each

230 kV Line P&C System

- Dual relays and fiber-optic channels
 - 87L
 - PUTT
 - 21/21N, 67N, and 79/25
- Bay controller
 - 50 BF
 - Switchgear control, interlocking, and circuit breaker supervision


Transformer Protection

- Dual relays
 - 87
 - High side – 51/51N and REF
 - Low side – 51/51N/51G
- Bay controller
 - 50 BF
 - Control, interlocking, and supervision
 - Data collection for SCADA

Distribution System Protection

- Protection and monitoring functions
 - All collector circuits – 50/51 and 50N/51N
 - Grounded collector circuits – 67N
 - 81 alarming
 - 59/27 alarming
- Fast bus tripping will be added to 34.5 kV bus


WTG Schematic Diagram




Type 4 WTG Response to Short Circuits

- WTG is ungrounded and contributes no zero-sequence current
- WTG current depends on control objective; not a natural generator response
- WTG control acts to balance currents and voltages during faults


Phase Overcurrent Protection Coordination Example



Bus Ground Fault Currents




Ground Overcurrent Protection Coordination Example



Actual Fault Event: April 8, 2015

- Initial energization of collector circuit caused two cross-country faults
- Permanent AG fault occurred on cable
- Lightning arrester failed on another circuit
- Tripped breaker left system ungrounded
- New lightning arrester failed on another circuit

Faulted Power System Section




Sequence of Events

Event	Time	Relay		
		3T91	3BF2	3LG22
1	12:50:17:146	Pick up	Pick up	
2	12:50:17:359	—	51N Trip $T_{OP} = 0.213 \text{ s}$	—
3	12:50:18:215	51N Trip $T_{OP} = 1.069 \text{ s}$	—	Pick up
4	12:50:18:779	—	—	Trip $T_{OP} = 0.564 \text{ s}$


Relay Currents

Current	Relay			
	3T91	TZ91	3BF2	3LF12
I_A	$2209.2 \angle 0^\circ$	$228.7 \angle 0^\circ$	$1482.4 \angle 0^\circ$	$540.4 \angle 0^\circ$
I_B	$1819.8 \angle 175.3^\circ$	$239.4 \angle 1.1^\circ$	$1513.7 \angle 296.8^\circ$	$545.8 \angle 291.7^\circ$
I_C	$326.3 \angle 41.2^\circ$	$247.4 \angle -2.9^\circ$	$83.1 \angle 275.6^\circ$	$28.6 \angle 206.3^\circ$
I_1	$1209.5 \angle 327.2^\circ$	$9.8 \angle 185.1^\circ$	$862.1 \angle 30.2^\circ$	$330.6 \angle 27.4^\circ$
I_2	$1114.9 \angle 28.6^\circ$	$3.6 \angle 88.8^\circ$	$45.9 \angle 73.7^\circ$	$22.3 \angle 69^\circ$
I_0	$245.7 \angle 29.6^\circ$	$238.4 \angle -0.7^\circ$	$867.9 \angle 326.6^\circ$	$295.2 \angle 324.1^\circ$
I_G	$736.8 \angle 29.6^\circ$	$715.1 \angle -0.7^\circ$	$2603.7 \angle 326.6^\circ$	$885.5 \angle 324.1^\circ$


Faulted Power System Section




First Fault: Relay 3T91 Record




First Fault: Relay TZ91 Record




First Fault: Relay 3BF2 Record




Faulted Power System Section




Faulted Power System Section




End of First Fault: Relay 3T91 Record



Faulted Power System Section



Second Fault: Relay 3BG2 Record



Conclusion

- Penonomé wind power plant: 270 MW, 108 WTGs
- Type 4 WTGs
 - Variable-speed wind turbine with synchronous generator and frequency converter
 - Power control and fault ride-through ability
 - Fault response determined by control system

Conclusion

- 230 kV P&C system includes
 - Dual 87L/PUTT 230 kV line protection
 - Dual step-up transformer protection
- 34.5 kV P&C system includes
 - Overcurrent protection for collector circuits
 - Additional 67N protection for grounded circuits
 - Fast-bus tripping (future)
- P&C system has performed well



Questions?