

# Practical Considerations When Protecting Mutually Coupled Lines

Craig Holt and Michael J. Thompson  
*Schweitzer Engineering Laboratories, Inc.*


Copyright © SEL 2016

## Overview

- What is mutual coupling?
- How is mutual coupling defined?
- What common configurations should be considered?
- What are the adverse affects on protection?
- What happens when settings are misapplied?

## Mutual Coupling


Creates complexities that require simplified network equivalents



$$V_{12} = I_1 \cdot Z_A + I_2 \cdot Z_M$$

$$V_{34} = I_2 \cdot Z_B + I_1 \cdot Z_M$$

## Defining Apparent Impedance



Impedance-based directional elements measure behind relay


$$Z_{OS\_APP} = \frac{\text{Re}[3V_0 \cdot (I_G \cdot 1\angle Z_0\text{ANG})^*]}{|I_G|^2}$$

Distance elements measure in front of relay

$$Z_{APP} = \frac{V_A}{I_A + k_0 \cdot 3I_0}$$

## Defining Coupling Strength

$$\%M = \left| \frac{Z_{0M}}{Z_{0L}} \right| \cdot 100$$




| Scenario | Proximity (feet)             | Z <sub>0M</sub> / Z <sub>0L</sub> (%) |
|----------|------------------------------|---------------------------------------|
| 1        | 14 (shared tower separation) | 69                                    |
| 2        | 114                          | 44                                    |
| 3        | 214                          | 36                                    |

## System Configurations

1. Single common bus
2. No common bus (electrically isolated systems in zero-sequence network)
3. Common buses
4. Mutually coupled line out of service and ungrounded (not analyzed)


## Configuration 1

### Natural




## Configuration 1

### By Breaker Operation




# Configuration 1


- F1, currents same direction, increased  $Z_{APP}$
- F2, currents in opposite direction, reduced  $Z_{APP}$




## Configuration 2 Natural Isolation



## Configuration 2 By Breaker Operation




## Configuration 2 Relative Isolation



## Configuration 2


### Line Out of Service and Grounded



$$Z_{0L\_APP} = Z_{0L1} - \frac{Z_{0M}^2}{Z_{0L2}}$$

## “Voltage Reversal”


- Relay 1 positive V0 out of phase with current
- Relay 2 negative V0 in phase with current



## Voltage Reversal

- Term is not useful for true Configuration 2
  - Reversal implies point of reference
  - Isolated system is not faulted
- Directional elements always declare forward
- Mutual coupling is series unbalance
- Polarizing quantities are result of induced current flow, so always forward


## Configuration 3






## Directional Decision Configuration 1

- Currents run in opposite directions
- $Z0S_{APP}$  is reduced




## Directional Decision Configuration 1

- $Z_{0S_{APP}}$  apparent source impedance is significantly reduced
- Relay misoperates for fault beyond 25% of coupled line with AUTO settings



## Significance Is a Function of Current



## Significance Is a Function of Current


$$Z0S_{APP} = \frac{Z0_{src2} - Z0_M + Z0_{L2} \cdot Z0_{src1}}{Z0_{src1} + Z0_M}$$

| Scenario        | $Z0_{src1}$ | $Z0_{src2}$ | $Z0S_{APP}$ |
|-----------------|-------------|-------------|-------------|
| Both strong     | 0.1         | 0.1         | 0.050       |
| Source 1 strong | 0.1         | 1.0         | 0.163       |
| Source 2 strong | 1.0         | 0.1         | 0.235       |
| Both weak       | 1.0         | 1.0         | 0.765       |

## Case Study

- DCB scheme misoperated
- System resembled Configuration 3 (at first glance)
- Behavior reflected Configuration 1


## Case Study



## Directional Decision Security Failure

- Not reverse enough

- Worst case  $Z0S_{APP}$ : 
$$Z0S_{APP} = \frac{Z0_{src2} - Z0_M + Z0_{L2}}{Z0_{src1} + Z0_M} \cdot Z0_{src1}$$




## Configuration 1 Analysis

- $Z0_M = 36\%$ , mutual coupling warrants consideration
- Configuration 1 was worst case for 32V element
  - $AUTO = Z0_L / 2 = 115 \Omega$
  - $Z0S_{APP} = 43 \Omega$
  - $Z0S_{APP} / 2 = 22 \Omega$
  - $AUTO2 = -2.175 \Omega$  ( $-0.3 \Omega$  secondary)
- $Z0S_{APP}$  for misoperation was  $71 \Omega$


## What About N-1 Conditions?

- Line 3 out of service with reclose condition can result in Configuration 2
- 32V element always declares forward regardless of Z0F setting


## What About N-1 Conditions?



## Ground Overcurrent Configuration 1




## Ground Overcurrent Configuration 1



## Ground Overcurrent and Distance Scenarios

1. System normal
2. N-1, strong ground source out at remote bus
3. Line 2 out of service and grounded
4. Fault in front of Breaker 3, Breaker 3 open
5. Fault in front of Breaker 3, Breaker 3 open with new strong ground source out

## Ground Overcurrent and Distance Scenarios



## Ground Overcurrent and Distance Worst Case May Not Be Same

| Scenario | Relay 1 $Z_{APP}$ ( $\Omega$ ) | Relay 1 $3I_0$ (A) |
|----------|--------------------------------|--------------------|
| 1        | 39.4                           | 143                |
| 2        | 46.2                           | 348                |
| 3        | 29.2                           | 363                |
| 4        | 51.1                           | 651                |
| 5        | 46.0                           | 661                |

## Directional Comparison Pilot Schemes Configuration 2

- Negative-sequence directional element
- Fault detectors
- Distance elements only in pilot schemes
- Negative-sequence supervision



## Summary

- Configuration 1 can result in extreme  $Z0S_{APP}$
- Configuration 2 results in “voltage reversal”
- Worst case for overcurrent and distance elements should not be assumed same
- Fault current in unfaulted line rises in Configuration 1 as fault moves away from shared bus on mutually coupled line

## Summary

- Apply negative-sequence directional elements exclusively on lines with significant (greater than 10%) mutual coupling – reduces risk of unexpected or unidentified Configuration 1 and 2 scenarios
- Remove sensitive directional ground overcurrent pilot tripping elements from high-speed pilot schemes
- Use larger margins

**Questions?**