



# Assessment of a misoperation on a distance protection relay by means of line impedance measurement and system-based testing

Moritz Pikisch, Rainer Luxenburger

Presenter: Eugenio Carvalheira

OMICRON electronics

10 March 2021

# Content

- > Impact on zero-sequence compensation factor on SLG faults**
- > Impedance measurements on different line topologies**
- > Measuring double circuit lines with the parallel circuit in operation**
- > Case study: Misoperation on a double-circuit line**


# Impedance Determination of a SLG fault

> AG fault, Location: m,  $R_F = 0\Omega$

$$> \frac{\bar{V}_a}{\bar{I}_a + \bar{k}_0 \bar{I}_r} = m \bar{Z}_{1L} \text{ where } \bar{k}_0 = \frac{(\bar{Z}_{0L} - \bar{Z}_{1L})}{3\bar{Z}_{1L}}$$

> Assumption:

- >  $Z_{1L}$  is correct
- >  $Z_{0L}$  is too high
- > Ex.: **AB** and **AG** Fault at  $m = 100\%$



## k0 for double circuit lines

>  $\bar{k}_0 = \frac{(\bar{Z}_{0L} - \bar{Z}_{1L})}{3\bar{Z}_{1L}}$  only applies to single circuit lines

- > In case of mutual coupling following factors also need to be considered:
  - > Mutual coupling Impedance  $Z_{0M}$
  - > Line Topology
    - > Lines terminate at same buses
    - > Lines terminate at different buses
  - > Infeeds and source impedances
  - > Switching state


## Measurement of $Z_1$ , $Z_0$ (and $Z_{0M}$ ), Part 1

- > No specific considerations necessary for
  - > positive-sequence impedance  $Z_1$
  - > single circuit lines
- > All mutually coupled circuits shut down at a time (possible only before commissioning):
  - >  $Z_0$  and  $Z_{0M}$  can be determined by measurement

## Measurement of $Z_1$ , $Z_0$ (and $Z_{0M}$ ), Part 2


- > Only one circuit out of service at a time:
- >  $Z_0$  can be affected by parallel live circuits
  - > Correction is possible by means of:
  - > Measure current in parallel live circuit
  - > Determine auxiliary impedance  $Z_{aux}$  from geometry of 6 phase conductors
  - >  $Z_{aux}$  therefore has the same accuracy as  $Z_1$ , calculated from geometry
- >  $Z_{0M}$  is calculated from  $Z_0$  and  $Z_{aux}$

## Topology of Double Circuit Line





## Overhead Line Section on same tower structure









## Location of the fault (End of Overhead Line in substation A)



# Sequence of CB tripping




Distance Relay Overreach!

## Line Impedance Measurement

|                         | $Z_1$ (R/X)    | $Z_0$ (R/X)           | $Z_{0M}$ (R/X)     |
|-------------------------|----------------|-----------------------|--------------------|
| Measured in $\Omega$    | 0,849<br>2,776 | 2,131<br>9,132        | 1,144<br>5,779     |
| Theoretical in $\Omega$ | 0,94<br>2,78   | 3,07<br>17,2          | Not present        |
| Error in %              | 10,85<br>0,13  | 44,71<br><b>88,29</b> | <b>Not present</b> |



- Error of  $Z_1$  is negligibly small, as expected
- Error of  $Z_0$  is significant, especially for X value which is relevant for distance relay performance
- Mutual Coupling Impedance hasn't been considered at all

## Simulation with Power System Model




- Observed Switching State: CB1 open. This is the state the relay of CB3 tripped off.
- Fault location is 200% from observed relay (CB3).

# Voltage and Current from Fault Record and Simulation



- Tuning Source Impedance to match with current -> Close match is possible
- Match of voltage is also pretty close which proves that simulation is very close to real conditions (real impedances seen from relay)

# Impedance versus Distance of Fault Location



# End-to-End Testing with PSS (Approach 1)

Power Sys. Parameters:


\* $Z_1$ ,  $Z_0$ ,  $Z_{0M}$

\*Loc. and Type of Fault

\*Topology

\*Infeeds


**Line Impedance Measurement**



- Prerequisite: Sequence of switching states and their durations must be known



# End-to-End Testing with PSS (Approach 2)



- Fully automated testing
- Real sequence of switching states is considered

## Comparison between alternative and common method

|                                 | $Z_1$ (R/X) | $Z_0$ (R/X) | $Z_{0M}$ (R/X) |
|---------------------------------|-------------|-------------|----------------|
| Common (in $\Omega$ )           | 0,849       | 2,131       | 1,144          |
|                                 | 2,776       | 9,132       | 5,779          |
| Minimum invasive (in $\Omega$ ) | 0,863       | 2,200       | 1,25           |
|                                 | 2,776       | 8,690       | 5,01           |
| Deviation in %                  | 1,65        | 3,24        | 9,27           |
|                                 | 0           | -4,84       | -13,3          |

- $Z_1$  is not affected by parallel live line, therefore no deviation
- $Z_0$  is quite accurate, about 4% off
- Deviation of  $Z_{0M}$  is 13%
- However, when simulating relay impedances the deviation is in the range of 4% which is acceptable for the application of distance protection.

## Conclusion

- > Impedances should be measured...
  - > ...and can be measured!
  - > Minimally-invasive measurement is a feasible option for double-circuit lines
- > Network Simulation Software...
  - > ...determines true impedances of SLG faults (Design)
  - > ...can be used to test relay with true V and I (Testing)

**Thank you!**

**[eugenio.carvalho@omicronenergy.com](mailto:eugenio.carvalho@omicronenergy.com)**