

New Methods in Power Line Carrier Monitoring and Analysis – Real World Examples and Implications for Protection System Reliability


Craig Palmer, Alan Jayson - *PowerComm Solutions*
Jeffrey Brown - *Georgia Transmission Corporation*

74th Annual Conference for Protective Relay Engineers
Texas A&M, March 24, 2021

Introduction

- Power Line Carrier has been protecting transmission lines in the US for at least 94 Years
 - *1927, Ohio Power Company, Newmark-Crooksville, 66 kV, 35 miles*
- Utilities find that many records of carrier channel events, even in this era, are not adequate for misoperation event analysis
 - *NERC Misoperations Report, 2013, etc.*
- Continuous monitoring devices, specific to PLC protection channels, provide enhanced carrier channel data
- “Improvements in data...help entities determine areas to improve by identifying misoperation causes and proper mitigation steps”
 - *NERC 2013*

How is the data obtained?



Wideband (to 5 MHz)

Sampling = 20 MHz

- RF transient detection
- Wideband level

Mid-band (10 kHz BW)

Sampling = 20 kHz

- Time-domain capture
- Spectral analysis

Narrow-band


300, 600, 1200 Hz typ.

- Impedance
- Levels, Freq, Trend

“New Methods” - Summary

- Trending: long-term storage of instantaneous data points, sampled at regular intervals (once an hour is typical)
 - *Levels (dBm), impedance / reflected power*
- Time-domain voltage capture / fast Fourier transform (FFT)
 - *400 ms of frequency-selective voltage “on the coax”*
 - *10 kHz BW at channel center frequency*
- Transient Detection
 - *Wideband voltage and current detected independently*
 - *Thresholds at ~300 V peak, ~2 A peak, min. 250 ns*
- Impedance – “where reflected power comes from”
 - *The impedance looking into the line tuner (typical installation)*
 - *Magnitude and phase (50 ohms 0 degrees ideal)*

Time-domain / FFT



Frequency analysis
of RED portion of
data shows 2 Tx
and 3 Rx signals

Composite voltage
signal in 10 kHz BW
(steady state)


Impedance vs Reflected Power

Z_{TERM}


$$\rho = \frac{Z_{TERM} - Z_{SOURCE}}{Z_{TERM} + Z_{SOURCE}}$$

$$RP_{(\%)} = 100 * \rho^2$$

Reflected
Power



Real-World Examples – Impedance and Phase




	Mag (Ω)	Phase (deg)	RP (%)
Baseline	49.8	0.0	0.0
Tuner input <i>shorted</i>	24.6	+84.3	85.2
Tuner ground sw. <i>shorted</i>	173.8	+86.5	93.4
CCVT ground sw. <i>shorted</i>	179	+85.9	92.9
Tuner input <i>open</i>	117.9	-88.8	96.9
Tuner prot. unit <i>open</i>	120.3	-88.6	96.5
Line disconnect <i>open</i>	88	-86.1	89.2



Power System Sources of PLC Noise

- Switching events generate transient carrier-band energy
 - *“Noise”*
- Transmitters/receivers are particularly helpless here
 - *No time-domain picture of the carrier – what did it look like??*
- New data help to observe the day-to-day interaction between PLC systems and the power system
 - *Signatures and characteristics*


Power System Related – Lightning




Power System Related – Breaker Operations



Power System Related – Line Disconnect




On-Off



Power System Related – Shunt Capacitor Banks


*Controlled switching and re-ignition
show up on carrier coax cable*




Carrier Holes

- “The lack of a signal where one should appear”
 - *Typically, due to some kind of flashover*
- “Tend to be a mystery”
 - *Available records show only the state of a relay contact, not the nature of the analog energy ultimately driving the relay contact*
- Block-hold timers - beware
 - *May mask carrier hole issues as they get progressively worse*
- Transient detection, time-domain, and FFT used for carrier holes


Carrier Holes




DCB – Observing Operations




DCB – Observing Operations



DTT Misoperation



DTT Misoperation



DTT Misoperation




Transient Monitoring

- Line traps isolate PLC systems from impedance changes on the bus
 - *And, from switching transients on the bus !!!*
- A failed trap tuning pack allows more carrier-band transient energy onto the line
 - *Once on the line, the energy has a tuned path to PLC receivers*
- Failing or de-rated gas tubes and spark gaps make transients worse
 - *Lower flashover means more flashovers*
 - *Carrier holes / loss of signal last longer*
- When these two factors combine – failed traps and de-rated gaps/tubes – misoperation risk is dramatically increased

Transient Monitoring

- Continuous monitoring devices can track baseline transient activity
 - *And indicate when it has increased beyond normal limits*



Implications for PLC Reliability

- NERC 2013 Misoperation Report (and subsequent reports)
 - *17% of misops caused by communications channel (396 of 2279)*
 - *12% of misops have “unexplainable” cause*
- Estimates made for the remaining groups' share of PLC
 - *30% of all communications-related misoperations involve PLC*
 - *5% of total protection misoperations*
- Trends continue to this day
- *Consistent use of continuous monitoring data for PLC can put a dent in this number*

Conclusions

“To only review data after obvious misoperations is analogous to a doctor ignoring your reports of anxiety, tightness in chest, nausea, and shortness of breath and only treating you for a heart attack if you experience cardiac arrest”

- *R. W. Patterson, “The Importance of Power System Event Analysis”*

- By using continuous monitoring data to inform PLC operations, maintenance, and analysis, utilities accomplish the following:
 - *Reduce effort, uncertainty, and costs associated with operating PLC channels for pilot protection of transmission lines*

Questions ?