

CT Saturation - A Simulation Study of Different Detection and Blocking Algorithms

Li Zou, Chee-Pinp Teoh, Ilia Voloh
GE Renewable Energy

2021 Texas A&M Protective Relaying Conference

Why handling busbar CT saturation is critical

- Substation bus supplies large area and many customers
- Security and stability are most important
- Substation busbar has connections to multiple sources that feed fault
- Fault current can be very large, with severe CT saturation



Operational requirements for Busbar protection


- The security and stability of busbar protection are of paramount importance
- Fastest possible internal faults clearance time to minimize equipment damage
- High selectivity, a differential relay does not need to have any intentional delay to coordinate with relays in adjacent zones.
- Ability to operate fast if fault evolves from external to internal (breaker flashover).

The problem – CT saturation


When exciting voltage is greater than CT knee point

- CT enters saturated region
- Exciting current is large

Slows tripping / unsecure tripping



(a)



(b)

The problem – CT saturation

- AC and DC components in primary fault current
- Burden
- Remanence



CT type and construction

- CT characteristics, magnetizing curve, knee-point voltage
- Magnetic cores: smaller size—but susceptible to saturation
- Air cores: less saturation—but larger size


CT saturation detecting and blocking algorithms

- First: detect saturation....then apply
- Detecting from waveform (sinewave-shape) recognition - **Method A**
- Detecting from differential locus trajectory in the Differential-Restraint plane – **Method B**
- Release blocking if fault evolves into internal




CT saturation detecting and blocking algorithms

Method A




(a)



(b)


CT saturation detecting and blocking algorithms

Method A



CT saturation detecting and blocking algorithms


Method A



CT saturation detecting and blocking algorithms


Method B

Assessing differential performance at low region and high region



CT saturation detecting and blocking algorithms

Method B




CT saturation detecting and blocking algorithms

Method B

Phase-comparison element (PCE) detects internal / external fault


$DIR = 1$

Internal fault: no current source is greater than 90-degrees apart



$DIR = 0$


External fault: one or more current sources are greater than 90-degrees apart



CT saturation detecting and blocking algorithms

Method B


Differential trajectory during CT saturation



CT saturation detecting and blocking algorithms


Method B

Increasing restrain during CT saturation is another measure for security



Evaluation Methodology and Test Results

Busbar for evaluation testing




Evaluation Methodology and Test Results

Influencing factors


- Fault type (ph-G, ph-ph, ph-ph-G and 3-phase faults)
- Fault location
- Fault resistance (to 260 ohms)
- Fault-current level (to 20 p.u.)
- Fault-inception point on wave (0° , 45° and 90°)
- Time to saturate ($1/8$, $1/4$ and $1/2$ cycle)
- Load-current level
- Vary CT remanent flux and the secondary burden for different times to saturate (TTS) and saturation severity

Evaluation Methodology and Test Results

External faults




(a) Phase A fault currents from all terminals




(b) Phase A differential and bias currents

Evaluation Methodology and Test Results

External faults-Method A blocks CT saturation




(a) Positive inhibit pulses



(b) Negative inhibit pulses


Inhibit pulses short differential current lobes




(c) Trip decision

Evaluation Methodology and Test Results


External faults-Method B fast detector involves PCE—ultimate security



(a) CT saturation detector output




(b) Phase comparison output




(c) Trip decision

Evaluation Methodology and Test Results

Internal faults- Deep saturation in 1/8 cycle can slow trip



(a) Phase A fault currents from all terminals




(b) Phase A differential and bias currents


Method A trips 10.8 ms after the fault inception. Method B trips in 3.3ms.

Evaluation Methodology and Test Results

Evolving faults- must respond quickly and securely



(a) Phase A fault currents from all terminals



(b) Phase A differential and bias currents

External A-G fault

Internal A-B-G fault

The trip decisions are made at 23 ms and 29 ms, respectively, after the fault evolution

Conclusions

- Method A: waveform-recognition technique
- Method B: trajectory based of bias and differential currents method; paired with phase-comparison element (PCE)
- Both methods remain stable for all external faults
- High-level security is consistent with theories of operation
- Both respond promptly to evolving faults—Method A faster tripping time
- Both enhance busbar protection and can decrease CT requirements
- Methodology presented can be used to verify any other algorithms or relays.

Thank You

Questions?