



## IDA Restoration- The Transmission Engineering Efforts

**Monir Hossain, Ph.D.**

**William A Rice**

**Tu Hy Nguyen**

**Scott C Brown**

**Shelbi Pigford**

**Entergy Services, Inc**


**New Orleans, LA**

March 2023



- A. Introduction
- B. Project Summary
- C. Relay Impact Study & Challenges
- D. Implementation
  - a. Solutions
  - b. Testing
- E. Conclusions

# Introduction



Hurricane Ida made landfall Aug. 29 at 11:55 CDT as an extremely dangerous Category 4 hurricane near Port Fourchon, Louisiana, with maximum sustained winds of 150 mph and gusts recorded reaching 172 mph in the area.

Ida's historic intensity caused severe damage to the Entergy distribution and transmission systems resulting in a peak of 948,000 outages in Louisiana and Mississippi.

# Introduction




## **Transmission Damages**

520 structures damaged

226 substations out


211 line branches out

# Introduction




The high winds of Hurricane Ida resulted in the catastrophic failure of a transmission line river crossing tower. With the Harahan to Avondale 230kV line out of service, multiple key industrials in South Louisiana are left radially sourced from Little Gypsy.

# Project Summary



**Post-IDA Network**



**Proposed Network**


## Proposed Solution

The team determined that the best solution for eliminating the radial would be to tie the Snake Farm to Labarre 230kV line to the Destrehan to Harahan 230kV line creating a 3-terminal line with Harahan acting as a tap.

# Project Summary: Point of Tapping the Two Lines




# Project Summary: Proposed Transmission Line work






# Relay Impact Study: Protection Challenges



Distance (21) Protection: Apparent impedance issue due to infeed


# Relay Impact Study: Protection Challenges



Miscoordination from overreaching during contingency conditions (no infeed)  
Violation of NERC loading compliance due to high reach  
Limitation of relay range

Distance (21) Protection: Limitation to set overreaching elements


# Relay Impact Study: Protection Challenges



Violation of NERC loading compliance due to high reach  
Limitation of relay range


Distance (21) Protection: Limitation to set overreaching elements

# Relay Impact Study: Protection Challenges



**Distance (21) Protection: Apparent impedance issue due to outfeed**


# Relay Impact Study: Protection Challenges



**Distance (21) Protection: Limitation to set underreaching elements**

# Relay Impact Study: Protection Challenges


1. The built-in POTT is configured for two-terminal line protection.
2. POTT scheme failure due to communication loss.
3. Weak infeed condition.



POTT Scheme


# Implementation: Solutions

1. Deployed new line differential protection panels.
2. Set Z1 (underreach element) to 80% of the minimum remote end without infeed.
3. POTT scheme with customized pass-through mirror bit.




POTT Scheme

4. Line differential scheme to cover all internal faults (irrespective of tap faults, weak infeed).



Terminal	1	2	3
$I_{remote}$	$I_B + I_C$	$I_A + I_C$	$I_A + I_B$
$I_{local}$	$I_A$	$I_B$	$I_C$





5. Customized Z2 supervision in case of both 87 and POTT schemes failure.

TRIP= .....+Z2T \* PSV31+.....

PSV31= (POTT Failure) AND (87 Failure)

- **Single-ended Element Test:**
  - I. Calculated V/I simulated in Power System Simulator.
  - II. Ensure individual protection function and alarm pickup.
- **End-to-End Test**
  - I. V/I from fault analysis software simulated in Power System Simulator.
  - II. Ensure comm. channel integrity.
  - III. Ensure POTT coordination, and differential functionality.

- Successful implementation within a week.
- Ensured N-2 transmission reliability for the area.
- Ensured N-1 relay coordination.
- Ensured NERC compliances.
- The implemented solution performed as intended for more than one year until the restoration of the original network (re-construction of Harahan-Avondale line).
- Saved 22k customers from outage during a fault event on 01-04-2022.

