

How to Determine the Effectiveness of Generator Differential Protection

Normann Fischer, Dale Finney,
and Douglas Taylor
Schweitzer Engineering Laboratories, Inc.

Overview

- Generator Stator Winding
- Typical Stator Winding Faults
- Differential Protection
- Detecting Stator Winding Faults
- CT Selection for Differential Protection
- Differential Protection Recommendations
- Conclusions

The Generator Stator

Stator Core




Stator Windings


Insulation



The Stator Core (Cylindrical)



The Stator Core (Hydro)




Example of Hydrogenerator Core



Types of Winding Structures

- Random-wound stators (< 300 kW)
- Form-wound stator using multiturn coils (< 100 MW) ✓
- Form-wound stator using Roebel bars (> 100 MW) ✓

Multiturn Coils



Insertion of a Multiturn Coil



Ludwig Roebel




1912




20 MW


Roebel Bars



Insulation Material




Typical Stator Winding Faults



Causes of Insulation Failure

- Thermal Deterioration
- Electrical Deterioration
- Mechanical Deterioration
- Environmental Deterioration


Thermal Deterioration




10°C increase temp = $\frac{A}{50} \frac{B}{T}$ % decrease life

Electrical Deterioration

Result of electrical stress within small voids in the insulation



Calculating the Electrical Stress (E) in the Void



$$C_{\text{air}} = \frac{\epsilon_0 \epsilon_r A_{\text{air}}}{d_{\text{air}}}$$

1st Approx. // plate

Calculate Electrical Stress in Void

$$V_{\text{air}} = \frac{C_{\text{ins}} \Delta V}{C_{\text{ins}} + C_{\text{air}}} \quad V_{\text{air}} = \frac{\frac{3}{4} \cdot 10 \text{ kV}}{\frac{3}{4} + \frac{1}{0.4}} \quad V_{\text{air}} = 2.31 \text{ kV}$$

$$E_{\text{void}} = \frac{V_{\text{air}}}{d_{\text{air}}} \quad E_{\text{void}} = 5.78 \text{ kV/mm}$$


Ground Wall
Insulation



Void


**Partial
Discharge**

Mechanical Deterioration



$$F = \frac{k \cdot A \cdot R (\epsilon \sin \theta \sin 2\theta)}{\text{Segments}}$$

Stator End Windings Support



Environmental Deterioration


Oil and Dust Contamination



Differential Protection Schemes


- Self-balancing differential
- Biased differential
- High-impedance differential
- Negative- and zero-sequence differential
- Restricted earth fault

Self-Balancing Differential




$$I_{MIN_SB} = CTR_{CB} \cdot I_{PU_SB}$$

Biased Differential




$$I_{MIN_BD} = 2 \cdot CTR_{BD} \cdot K_{BD} \cdot I_{RATED}$$

High-Impedance Differential




$$I_{MIN_HZ} = CTR_{HZ} \cdot I_{PU_HZ}$$

Negative- and Zero-Sequence Differential



$$I_{MIN_QG} = CTR_{QG} \cdot I_{PU_QG}$$

Restricted Earth Fault



$$I_{MIN_REF} = CTR_{REF} \cdot I_{POL_REF}$$

Comparison of Scheme Sensitivities

Assumed values


Scheme Variable	Value
CTR_{PH}	1200/5
CTR_{CB}	100/5
$I_{pkp_{SB}}$	0.25 A sec.
K_B	25%
$I_{pkp_{HZ}}$	0.1 A sec.
I_{pkp_Q}	0.25 A sec.
$I_{pol_{REF}}$	0.25 A sec.

Sensitivities in
amperes primary


Scheme Type	Imin
Self-Balancing	5
Biased	600
High Impedance	24
Negative Sequence	60
Restricted Earth Fault	60

Detecting Stator Winding Faults


RTDS Model





Phase-to-Ground Faults




Phase-to-Phase Faults



Turn-to-Turn Faults



Turn-to-Turn Faults



CT Selection for Differential Protection

- CT ratio
 - ◆ Sensitivity vs security
 - ◆ Full load current \approx nominal CT current
- CT voltage rating
 - ◆ Ideal $V_{KNEE} > (1 + X/R)$
 - ◆ Minimize burden impedance (Z_{MIN})
 - ◆ Select highest possible V_{KNEE}

Differential Protection Application Recommendations

- Use identical CTs for machine neutral and terminal
- Set minimum pickup current below minimum fault current
- Slope setting determined by maximum CT error for a through fault

$$\begin{aligned}\text{Worst case: } IOP_{ERR} &= (1 + \varepsilon)I_{NEU} - (1 - \varepsilon)I_{TERM} \\ &= 2\varepsilon\end{aligned}$$

Recommendations if CT Saturation Occurs for Through Faults

- Increase slope setting to greater value
(sacrifices sensitivity)
- Employ relay with ac and dc external fault detection logic
(maintains sensitivity and adds security)

Conclusions

- Discussed factors that influence design of stator windings in synchronous generators
- Presented and compared various differential protection methods
- Simulated internal faults using an RTDS model
 - ◆ Phase, negative-, and zero-sequence differential elements can detect phase-to-phase faults
 - ◆ Differential elements are also effective for detecting ground faults

Conclusions

- RTDS simulation indicated that differential elements are not effective in detecting turn-to-turn faults
- RTDS model limitations
 - ◆ Cannot simulate faults close to neutral
 - ◆ Can only simulate single-winding turn faults

Questions?

