

# Modern Protection of Three-Phase and Spare Transformer Banks

Michael Thompson, Faridul Katha Basha, and Craig Holt  
*Schweitzer Engineering Laboratories, Inc.*

Copyright © SEL 2016

## Agenda

- Introduction
- Three-single-phase-and-spare (TSPS) configurations
- Transformer protection fundamentals
- TSPS modern protection applications
- Configurable transformer compensation matrix
- Conclusion

## Introduction

- Large transformers – expensive, long lead times
- TSPS transformers – fault tolerance
- Extensive outage time for identifying and isolating failed transformer and substituting a spare
- Complex rewiring of protection system to insert spare transformer
- Spare idled for long duration

## Design Objectives

- Reduce outage duration
- Simplify substitution of spare transformer
- Promote periodic switching of spare transformer
- Apply modern microprocessor technology
  - Precise identification of faulted unit or lead bus phase
  - Automatic and quick reconfiguration of protection zones


## Two TSPS Transformer Applications Considered

- Transmission autotransformer
- Generator-step-up (GSU) transformer




### TSPS Configuration 1 Dedicated Spare

- Dedicated spare transformer substituted for any normally in-service transformers
- Switches and buswork links for reconfiguration



## TSPS Configuration 2 No Dedicated Spare

- Single-phase transformer cannot be substituted for all three phases
- Lead bus of any phase can only be switched between two single-phase units



## Transformer Protection Fundamentals

- Transformer differential protection requires ampere-turn balance (ATB) equations for magnetic circuit
- Single-phase transformers have closed magnetic circuit
- ATB equations can be written on a per-phase basis
- Zero-sequence compensation (delta compensation) is not required, hence it enables faulted-tank identification


## ATB Differential Protection

ATB Equation for  
Single-Phase Transformer

$$AT = (n_s + n_c) \cdot i_H + n_c \cdot i_X + n_Y \cdot i_Y = 0$$

Tap Equation

$$TAPn = \frac{MVA_{T1\Phi} \cdot 1000}{KVn_{WINDING} \cdot CTRn}$$



## Partial-Winding Fault Protection

- Turn-to-turn and turn-to-ground faults
- Phase differential (less sensitive)
- Sensitivity of protection (critical)
- Partial winding fault protection schemes
  - Fault pressure relay (63 w/50P)
  - Restricted earth fault (REF)
  - Negative-sequence differential (87Q)


## Modified REF Scheme

- Scheme is implemented in lead bus, low-impedance differential relays
- Lead bus relays include three unused differential elements
- Ground differential is created around each in-service tank
- Zone switching logic easily accommodates spare substitution
- Scheme uses Kirchoff's current law and not ATB differential, so is immune to effects of magnetic circuit


## Negative-Sequence Differential Protection (87Q)

- Provides superior sensitivity
  - 87Q is not restrained by load flow
  - External fault detector enhances security
- Complements 63 w/50P and REF
- Spare substitution may result in incomplete three-phase current sets

## Autotransformer Protection Option 1 Main A System, Overall Differential



## Autotransformer Protection Option 1 Main B System, Separated Zones



## Overall Differential


Three-Phase CT Inputs  
S, T, and U Not Shown

S, T, U, X = M0

1	0	0
0	1	0
0	0	1

W = Disabled

0	0	0
0	0	0
0	0	0




## Overall Differential


- 87TA/O-1 performs differential protection using ATB per phase
- 87TA/O-2 performs conventional differential (if tertiary is unloaded)
- Tertiary bus differential is via separate relay or 87P-BYT
- 87TA/O-1 and 87TA/O-2 functionally interchanged for T3 and T4 transformer out of service (TOOS)




## GSU Protection



## GSU Protection Option 2






## Configurable Compensation Matrix (M13)

- Matrix is proposed for applications involving complex compensation
- Single relay can accommodate all TSPS configurations
- Functionality is not sacrificed
- ATB is per phase and provides faulted-phase identification
- M13 is future application for special cases

**T4 TOOS**

	S = M0			T = M0			U = M0			W = M0			X = OFF		
87A	1	0	0	1	0	0	1	0	0	1	0	0	0	0	0
87B	0	1	0	0	1	0	0	1	0	0	1	0	0	0	0
87C	0	0	1	0	0	1	0	0	1	0	0	1	0	0	0
	IAS	IBS	ICS	IAT	IBT	ICT	IAU	IBU	ICU	IAW	IBW	ICW	IAX	IBX	ICX

## Matrix M13



## Conclusion

- TSPS transformers improve fault tolerance and availability
- Single-phase transformers allow ATB per phase and positive faulted-phase indication
- Proposed schemes using modern microprocessor-based relays enable quick insertion of spare on correct phase

## **Conclusion**

### **Goals of Modern Protection Schemes**

- Sensitive and redundant protection for all faults
- Identification of right phase and equipment
- Elimination of CT wiring reconfiguration
- Reduced outage times (from days to hours)
- Novel CT circuits (easy to wire and test)
- Automatic reconfiguration of zones via pushbuttons or switch statuses

**Questions?**